

SEP 20 2013

Mr. Christopher A. Lund, P.E.
Receiver Representative
Gershman, Brickner, & Bratton, Inc.
Fairfax, VA 22031-4620

Re: Ordot Dump Closure and Dero Road Sewer Improvement Project
Project No. GSWA-002013, 100% Design Submittal and Construction
Permit Approval

Hafa Adai Mr. Lund:

The Guam Environmental Protection Agency (GEPA) conditionally approved the 100% design submittal and construction permit application of the above reference project with the following conditions:

- The contractor must submit a separate Clearing, Grading and Stockpiling Permit application and must pay any associated permit fee pursuant to Guam Soil Erosion and Sediments Control Regulations;
- The contractor must submit a separate Erosion Control Plan (ECP) and Environmental Protection Plan (EPP) specific to the scope of works mentioned in the approved drawing and specification. Such plan must indicate the soil materials staging area and all Best Management Practices (BMPs) prior to commencement of any civil work. Contractor must request inspection from GEPA, Water Pollution Control Program for the temporary BMPs prior to start of any work;
- The scope of work mentioned in the Wetland Mitigation Plan must be included in the construction drawing and contract agreement to insure compliance with the condition stipulated in the building permit clearance from GEPA;
- All above ground oil storage tanks with a capacity of 55 gallons or greater must be provided with secondary containment;
- Generator room must be provided with a minimum of 4" thick perimeter concrete berm with a lockable drain valve;

- An Air Emission permit for the emergency generator must be obtained from GEPA, Air and Land Division prior to issuance of occupancy permit clearance by the Agency.

Should you have any questions, need additional information or would like a copy of the regulations referenced in this letter, please contact Mr. Angel B. Marquez, Acting Chief Engineer via email at Angel.Marquez@epa.guam.gov or call (671) 300-4796.

Si yu'us ma'ase,



WALTER LEON GUERRERO
Acting Administrator

cc: Mr. Carl Dominguez, Director, DPW
Ms. Karen Ueno, Consent Decree Project Manager, USEPA Region IX
Mr. Paul Baron, GHD